

Courtroom Audio Visual System
Request for Proposal: Questions & Responses

July 22, 2015

1. How many microphones are currently being used? Do you want to add any more?

Courtroom 1 uses 8 microphones. Courtroom 2 uses 5 microphones. No, we do not want to add any microphones.

2. What is the model of the call manager or bridge of the existing Cisco VOIP system?

Refer to the online posting of the Questions and Answers dated July 17, 2015.

3. Who will install the electrical outlets for monitors, etc.?

Refer to the online posting of the Questions and Answers dated July 17, 2015.

4. Where is the equipment housed? If in rack, will you need to replace an old rack or cabinet to include new updated system?

Equipment is housed in a rack in a closet within each courtroom. The existing racks may need to be replaced.

5. How many ALS devices are required?

Two total, one for each courtroom.

6. Do you want connection plate mounted in tables, or table box mounted in table with cables that pull out? How many document cameras?

Refer to Additional Technical Details appended to the online posting of the Questions and Answers dated July 17, 2015. Two document cameras are needed; one for each courtroom.

7. Will the VTC be shown on the two 60 inch displays? If not, what will display this?

Yes.

8. What is the height from floor to ceiling? What type of existing wall do you have for the 60 inch display mounts, drywall?

The height from floor to ceiling is 8 feet, 4 inches. Yes, drywall with metal studs.

9. Will VTC camera be wall mounted? Where? How far will camera be from housed Codec?

Yes, cameras will be wall mounted. Refer to Additional Technical Details appended to the online posting of the Questions and Answers dated July 17, 2015.